

# Coventry Public Schools

Physical Plant and Facilities

78 Ripley Hill Road Coventry, CT 06238 (860) 742-4525

4/7/11

Coventry High School  
78 Ripley Hill Rd  
Coventry, CT 06238

Dear Parents and Staff:

The Coventry Public Schools has conducted comprehensive radon testing in accordance with Connecticut General Statute (CGS) 10-220(d), the Connecticut Department of Public Health School Radon Testing Guidance and the United States Environmental Protection Agency. Sampling was done between the dates of March 7, 2011 and March 10, 2011. This represents 10% of all the frequently occupied rooms in contact with the ground, first floor and below ground level areas. Initial testing of 100% of these frequently occupied areas done in March 2006, yielded radon levels well below the EPA and CT DPH action level of 4.0 pCi/l.

Results indicate that radon levels for this testing period are below the action level. No remediation is required. The complete report is available for viewing in the main office.

If you have any questions or concerns, please feel free to contact me at (860) 742-4525.

Thank you for your cooperation during this sampling period.

Sincerely,

Paul Noel  
Director of Physical Plant & Facilities